IAES Journal of Electrical and Electronics Engineering
Vol. 4, No. 1, June 2017, pp. 13~16
ISSN: 2338-7432, DOI: 10.11591/jeee.v4i1.pp13-16

Smart grids in the era of artificial intelligence: advances in load forecasting, fault diagnosis, and energy management

Watra Arsadiando, Hendril Satrian Purnama
Embedded Systems and Power Electronics Research Group, Yogyakarta, Indonesia

Article Info

Article history:

Received Jun 18, 2016
Revised Dec 27, 2016
Accepted Feb 15, 2017

Keywords:

Artificial intelligence
Demand response
Energy management
Load forecasting
Machine learning
Multi-agent systems
Smart grid

ABSTRACT

The development of smart grids has transformed conventional electricity networks into interconnected systems capable of collecting, processing, and exchanging operational information. However, increasing electricity demand, distributed renewable generation, and changing consumption patterns have introduced challenges in forecasting, fault identification, and energy management. Artificial intelligence (AI) offers opportunities to address these challenges through data-driven prediction, intelligent classification, and adaptive decision-making. This review examines the application of AI techniques in three important smart grid functions: load forecasting, fault diagnosis, and energy management. It discusses artificial neural networks, support vector machines, hidden Markov models, optimization algorithms, and multi-agent systems, with particular attention to research published up to 2016. The review also identifies technical limitations and research priorities for developing more reliable, efficient, and adaptive smart grid infrastructures.

This is an open access article under the CC BY-SA license.

1. INTRODUCTION

Conventional electricity networks were primarily designed to deliver power from centralized generation facilities to consumers through relatively predictable transmission and distribution structures. The increasing penetration of distributed generation, renewable energy resources, electric vehicles, and advanced metering infrastructure has changed this operating environment. Modern electricity networks must now accommodate bidirectional power flows, variable generation, dynamic consumption, and a growing volume of operational data. These developments have encouraged the transition toward smart grids, where communication technologies and intelligent information processing support more coordinated electricity system operation [1].

Despite their potential, smart grids introduce several technical and operational challenges. Electricity demand varies according to weather conditions, consumer behavior, economic activity, and time-dependent usage patterns, making accurate forecasting essential for system planning and operation. At the same time, increasingly interconnected networks require reliable fault detection and diagnosis to prevent local disturbances from developing into wider service interruptions. Effective energy management is also necessary to coordinate generation, storage, demand response, and power exchange while maintaining acceptable cost and reliability levels.

Conventional statistical models, protection mechanisms, and centralized energy management approaches remain important foundations for electricity system operation. Nevertheless, their performance may be limited when systems exhibit nonlinear behavior, uncertain operating conditions, and large volumes of heterogeneous measurements. Artificial intelligence (AI) provides complementary techniques that can learn patterns from historical data, recognize abnormal operating conditions, and support decisions involving multiple constraints. This review therefore examines the contribution of AI to load forecasting, fault diagnosis, and energy management, while considering the challenges associated with practical smart grid implementation.

2. AI-BASED LOAD FORECASTING

Load forecasting is a fundamental smart grid function because operational decisions depend on anticipating electricity demand at different time horizons. Short-term forecasts support generation scheduling, reserve allocation, and electricity market operation, whereas medium- and long-term forecasts contribute to infrastructure planning and investment decisions. Forecasting becomes more complicated when demand is influenced by distributed generation, flexible loads, electric vehicles, and changing consumer behavior. Accurate prediction is therefore important not only for balancing supply and demand but also for improving the economic operation of the entire electricity network.

Artificial neural networks (ANNs) have been widely investigated because they can learn nonlinear relationships between historical electricity consumption and relevant external variables. Hippert, Pedreira, and Souza reviewed neural network applications in short-term load forecasting and identified important issues concerning model architecture, training procedures, and evaluation methods [2]. Their analysis highlighted that forecasting performance depends on more than selecting a sophisticated network structure. Data preparation, representative training samples, and consistent testing procedures are equally important for obtaining dependable results.

Support vector machines and support vector regression provide alternative approaches for modeling nonlinear demand patterns. These methods can be particularly useful when the available dataset is relatively limited or when conventional assumptions about demand behavior are unsuitable. Raza and Khosravi reviewed AI-based load forecasting techniques for smart grids and buildings, discussing the potential of different learning methods across forecasting applications [3]. Alamaniotis, Bargiotas, and Tsoukalas also investigated kernel machine regression for medium-term electricity load forecasting, demonstrating the relevance of data-driven methods to smart energy systems [4].

Forecasting uncertainty is another important consideration because a single predicted demand value cannot fully represent the range of possible operating conditions. Quan, Srinivasan, and Khosravi proposed neural network-based prediction intervals for short-term load and wind power forecasting, providing information about forecast uncertainty rather than relying exclusively on point predictions [5]. This approach is relevant to smart grids because uncertain demand and renewable generation can influence reserve requirements and operational risk. Consequently, future forecasting systems should combine predictive accuracy with meaningful uncertainty information.

3. INTELLIGENT FAULT DIAGNOSIS IN SMART GRIDS

Fault diagnosis is essential for maintaining the reliability and continuity of electricity supply. Traditional protection systems detect abnormal electrical conditions and isolate affected network sections through protective devices. However, modern smart grids provide additional information from smart meters, phasor measurement units, intelligent electronic devices, and communication networks. These data sources create opportunities for intelligent diagnosis systems that can identify abnormal patterns, estimate fault locations, and support faster restoration decisions.

Machine learning techniques can recognize abnormal operating patterns by analyzing voltage, current, frequency, and other measurements. Jiang et al. developed a data-driven fault detection, identification, and location approach using signal decomposition, hidden Markov models, and machine-learning-based fault analysis [6]. Their work demonstrated how information extracted from electrical signals could support the identification of different fault conditions. Such methods are particularly relevant when conventional protection information alone is insufficient to provide detailed diagnostic insight.

Synchrophasor measurements provide another valuable source of information for intelligent fault diagnosis. Jiang et al. investigated spatial-temporal characterization and analytics of synchrophasor data for fault detection, identification, and causal impact analysis in smart grids [7]. Their approach combined measurement processing with data-driven analysis to examine disturbances and their relationships across network locations. This demonstrates the potential of combining advanced measurement infrastructure with intelligent algorithms to improve grid situational awareness.

However, intelligent fault diagnosis must distinguish genuine equipment abnormalities from measurement errors, communication failures, and normal operational variations. A diagnostic model trained using a limited set of fault scenarios may fail to recognize unfamiliar disturbances or changing network configurations. False alarms can also lead to unnecessary switching operations and additional operational costs. Therefore, reliable diagnosis requires representative datasets, appropriate validation, and coordination with established protection and restoration procedures.

4. AI AND INTELLIGENT ENERGY MANAGEMENT

Energy management in smart grids involves coordinating electricity generation, consumption, storage, and exchange to achieve operational and economic objectives. The increasing use of distributed energy resources makes this task more complicated because generation and consumption may be located across many independently operated network components. Energy management systems must therefore consider power balance, operational constraints, electricity prices, equipment limitations, and consumer requirements. AI-based decision support can help coordinate these variables and improve the flexibility of smart grid operation. Demand response is one of the important applications of intelligent energy management. It allows electricity consumption to respond to price signals, incentives, or direct control instructions rather than relying exclusively on adjustments to electricity generation. Vardakas, Zorba, and Verikoukis reviewed demand response programs in smart grids, including pricing mechanisms and optimization algorithms for coordinating consumer behavior [8]. These approaches can help reduce peak demand, improve resource utilization, and support the integration of variable renewable generation.

Multi-agent systems provide another approach to distributed energy management. In this architecture, individual agents represent components or stakeholders such as generators, storage devices, consumers, and network operators. Each agent can make decisions according to local objectives while exchanging information with other agents to coordinate system-level operation. McArthur et al. reviewed multi-agent systems for power engineering applications and discussed their potential, technical requirements, and implementation challenges [9].

Khan, Jidin, and Pasupuleti proposed a multi-agent-based distributed control architecture for microgrid energy management and optimization [10]. Their work addressed limitations associated with centralized management, particularly the need for adaptability and fault tolerance in distributed environments. Distributed intelligence can allow local decisions to be made closer to the relevant resources while maintaining coordination across the microgrid. Nevertheless, communication reliability, interoperability, and coordination among agents remain important implementation considerations.

5. COMPARATIVE ANALYSIS AND INTEGRATION OF AI FUNCTIONS

The three AI application areas discussed in this review serve different but complementary purposes. Load forecasting estimates future operating conditions, fault diagnosis identifies abnormal system behavior, and energy management determines how available resources should be coordinated. Their combined operation can support a more responsive smart grid than the isolated deployment of individual algorithms. Table 1 summarizes the principal techniques, their applications, and their main limitations.

Table 1. Comparison of AI techniques for smart grid applications

AI technique	Primary application	Main contribution	Main limitation
Artificial neural networks	Load forecasting	Learns nonlinear demand patterns	Requires representative training data
Support vector regression	Load forecasting	Models complex demand relationships	Sensitive to parameter selection and data preprocessing
Prediction interval models	Load and renewable forecasting	Represents forecast uncertainty	Requires suitable uncertainty evaluation
Hidden Markov models	Fault detection and diagnosis	Identifies abnormal temporal patterns	Performance depends on model assumptions and training data
Signal processing and machine learning	Fault identification and location	Extracts disturbance features and classifies events	Sensitive to measurement quality and network conditions
Optimization algorithms	Demand response and scheduling	Supports resource allocation and operational decisions	May require substantial computation
Multi-agent systems	Distributed energy management	Enables local decision-making and coordination	Requires reliable communication and interoperability

As shown in Table 1, each method addresses a particular aspect of smart grid intelligence rather than providing a complete solution independently. Neural networks and support vector regression are primarily concerned with learning demand patterns, while hidden Markov models and signal-processing techniques support abnormal-event analysis. Optimization algorithms and multi-agent systems are more directly associated with coordinating operational decisions. The comparison suggests that effective smart grid intelligence requires an architecture that connects prediction, diagnosis, and management instead of treating them as separate applications.

An integrated smart grid architecture could use forecasting results to anticipate demand and renewable generation before operational decisions are made. Fault diagnosis could then monitor network measurements and provide information about abnormal conditions that may affect the availability of equipment or network sections. Energy management could use both sources of information to revise generation schedules, storage

operation, demand response, or restoration priorities. Such coordination could improve operational flexibility, although it requires reliable data exchange and appropriate decision-making priorities.

6. RESEARCH CHALLENGES AND FUTURE DIRECTIONS

The practical implementation of AI in smart grids faces several challenges related to data quality, scalability, and system reliability. Smart grid measurements may contain missing observations, communication delays, inconsistent sampling rates, and sensor errors that affect learning and diagnosis. In addition, models developed for one network configuration may not perform equally well when transferred to another utility or geographical area. These issues make data governance, model validation, and interoperability essential requirements for intelligent grid applications.

Cybersecurity and privacy also deserve careful consideration because smart grids depend on extensive communication and data exchange. Consumer load profiles may reveal sensitive information about household activities, while compromised measurements could influence forecasting, protection, or energy management decisions. Intelligent systems must therefore operate alongside suitable authentication, access control, communication security, and data protection mechanisms. AI should strengthen operational intelligence without creating additional vulnerabilities in the electricity infrastructure.

Future research should emphasize integrated and distributed intelligence that can operate under uncertain conditions. Hybrid architectures combining physical system models, machine learning, optimization, and multi-agent coordination may offer a practical balance between data-driven flexibility and engineering reliability. Further attention should also be given to explainable decision-making, real-time implementation, and validation using operational utility data. These developments are necessary to move intelligent smart grid technologies from experimental applications toward dependable large-scale deployment.

7. CONCLUSION

AI provides valuable capabilities for addressing the operational challenges of modern smart grids. Neural networks and support vector methods can improve load forecasting, while hidden Markov models and data-driven signal analysis can support fault detection and diagnosis. Optimization algorithms, demand response strategies, and multi-agent systems can improve the coordination of distributed resources and energy consumption. Together, these techniques provide a foundation for more informed and adaptive electricity network operation. However, the benefits of AI depend on reliable data, appropriate model validation, secure communication, and coordination with established power system practices. Forecasting, diagnosis, and energy management should be developed as interconnected functions rather than isolated computational applications. Future smart grids will benefit from intelligent architectures that combine predictive information, fault awareness, and distributed decision-making while preserving operational safety and reliability. Such integration can contribute to more efficient, resilient, and flexible electricity networks.

REFERENCES

[1] X. Fang, S. Misra, G. Xue, and D. Yang, "Smart grid - the new and improved power grid: a survey," *IEEE Communications Surveys and Tutorials*, vol. 14, no. 4, pp. 944–980, 2012, doi: 10.1109/SURV.2011.101911.00087.

[2] H. S. Hippert, C. E. Pedreira, and R. C. Souza, "Neural networks for short-term load forecasting: A review and evaluation," *IEEE Transactions on Power Systems*, vol. 16, no. 1, pp. 44–55, 2001, doi: 10.1109/59.910780.

[3] M. Q. Raza and A. Khosravi, "A review on artificial intelligence based load demand forecasting techniques for smart grid and buildings," *Renewable and Sustainable Energy Reviews*, vol. 50, pp. 1352–1372, 2015, doi: 10.1016/j.rser.2015.04.065.

[4] M. Alamaniotis, D. Bargiotas, and L. H. Tsoukalas, "Towards smart energy systems: application of kernel machine regression for medium term electricity load forecasting," *SpringerPlus*, vol. 5, no. 1, pp. 1–15, 2016, doi: 10.1186/s40064-016-1665-z.

[5] H. Quan, D. Srinivasan, and A. Khosravi, "Short-term load and wind power forecasting using neural network-based prediction intervals," *IEEE Transactions on Neural Networks and Learning Systems*, vol. 25, no. 2, pp. 303–315, 2014, doi: 10.1109/TNNLS.2013.2276053.

[6] H. Jiang, J. J. Zhang, W. Gao, and Z. Wu, "Fault detection, identification, and location in smart grid based on data-driven computational methods," *IEEE Transactions on Smart Grid*, vol. 5, no. 6, pp. 2947–2956, 2014, doi: 10.1109/TSG.2014.2330624.

[7] H. Jiang, X. Dai, D. W. Gao, J. J. Zhang, Y. Zhang, and E. Muljadi, "Spatial-temporal synchrophasor data characterization and analytics in smart grid fault detection, identification, and impact causal analysis," *IEEE Transactions on Smart Grid*, vol. 7, no. 5, pp. 2525–2536, 2016, doi: 10.1109/TSG.2016.2552229.

[8] J. S. Vardakas, N. Zorba, and C. V. Verikoukis, "A survey on demand response programs in smart grids: pricing methods and optimization algorithms," *IEEE Communications Surveys and Tutorials*, vol. 17, no. 1, pp. 152–178, 2015, doi: 10.1109/COMST.2014.2341586.

[9] S. D. J. McArthur *et al.*, "Multi-agent systems for power engineering applications - Part I: Concepts, approaches, and technical challenges," *IEEE Transactions on Power Systems*, vol. 22, no. 4, pp. 1743–1752, 2007, doi: 10.1109/TPWRS.2007.908471.

[10] M. R. Basir Khan, R. Jidin, and J. Pasupuleti, "Multi-agent based distributed control architecture for microgrid energy management and optimization," *Energy Conversion and Management*, vol. 112, pp. 288–307, 2016, doi: 10.1016/j.enconman.2016.01.011.